



Memo No. 4633

Dated 17/8/2021

To

The Principal
Manaskriti School
Sector-82, Faridabad

Subject: - NOC for building structure safety certificate of Manaskriti School Sector - 82 Faridabad.

Reference: - Your office letter No. MKS/2021-22/045 Dated 19.07.2021

In this connection of above cited subject, it is submitted that the above said school building was inspected by Sub Divisional Engineer, Provincial Sub Division No.2, PWD B&R Br., Faridabad alongwith concerned Junior Engineer on dated 16.08.2021. The school building having 2 Blocks (1&2) & Both Block having Lower Ground Floor, Ground floor, First Floor, Second Floor.. Following are the features of the building observed during the inspection of the school:-

**BLOCK 1 :-
(LOWER GROUND FLOOR):-**

- At Lower Ground floor, There are 1 No. Hall, 2 No. Store rooms

GROUND FLOOR:-

- At ground floor there are 5 No. Classroom, 2 No. Washroom, 1 No. Office room

FIRST FLOOR:-

- At first floor there are 5 No. Classrooms, 2 No. Washroom, 1 No. Hall, 1 No. Lab, 1 No. Staff room

SECOND FLOOR:-

- At first floor there are 5 No. Classrooms, 1 no. Activity room, 1 No. Lab, 2 No. Washroom, 1 No. Staff room

**BLOCK 2:-
(LOWER GROUND FLOOR):-**

- At Lower Ground floor there are 5No. Classroom, 2 No. Activity Classroom, 2 No. Washroom

GROUND FLOOR:-

- At ground floor there are 5 No. Classroom, 1 No. Hall, 1 No. Meeting room , 1No. Medical room , 2 No. Washroom , 1 No. Staff room , 1 No. School pantry

FIRST FLOOR:-

➤ At first floor there are 5 No. Classrooms, 1 No. Music room , 1 No. Library , 1 No. Art & craft room , 1 No. Staff room , 2 No. washrooms


SECOND FLOOR:-

➤ At first floor there are 5 no. Classrooms, 1 no. Activity room, 2 No.Washroom.

The building is having frame structure with column beams and R.C.C. slab & load bearing walls of Block (1) & the structure of Block (2) of steel girders with R.C.C slab. The structure stability certificate has been also enclosed, which issued by Global Design Engineers Consulting Engineer & Project Managers vide his Ref. No. Cert/G&G/str/01/22 dated 16.08.2021. The fire NOC has been issued by Sr. Fire station officer Faridabad vide his Endst. No. FSO/2018/F-952/1127 dated 19.03.2018 & valid for 5 years. The hygiene certificate is also issued by O/o Civil Surgeon, Faridabad vide their office No. SH/2019/147 dated 16.09.2019

Keeping in view all the circumstances and the documents submitted by the applicant, the building is seems to be safe. The building safety certificate is issued to the above mentioned school for the time period of one year. The periodical inspection of the school building must be ensured.

DA/Nil



Executive Engineer
Provincial Division
PWD B&R Br., Faridabad

Endst No.

Date

Copy of above is forwarded to the Sub Division Engineer, Provincial Sub Division No.2, PWD B&R Br., Faridabad w.r.to his letter no. 778 dated 17.08.2021.

DA/Nil


Executive Engineer
Provincial Division
PWD B&R Br., Faridabad